

VALVE ASSEMBLY DETAIL


NOT TO SCALE

NOTES:

1. COMBINATION AIR RELEASE AND VACUUM VALVE SHALL BE A 2" SIZE MINIMUM -UNLESS OTHERWISE SHOWN ON THE CONSTRUCTION DRAWINGS.
2. FOR 1" COMBINATION VALVE INSTALL 2"x1" REDUCER BETWEEN GATE VALVE AND UNION.
3. FILL METER BOX WITH SAWDUST AFTER TESTING AND INSPECTION.
4. INSTALL STD. MARKER POST IDENTIFYING VALVE LOCATION (NOT SHOWN).
5. SET METER BOX FLUSH WITH SIDEWALK OR CURB ELEVATION IF LOCATED IN LAWN AREA. SET METER BOX APPROX. 2-INCHES ABOVE FINISHED GRADE IF IN LANDSCAPING AREA.

APPROVED: WILLIAM J. CAMPBELL

REV. DATE: JULY 01, 2007



STANDARD DETAILS

COMBINATION AIR RELEASE AND VACUUM VALVE ASSEMBLY

WATER/WASTEWATER DIVISION

FILE SD706.DGN DRAWING NO. 706